

深圳妈湾电力有限公司2019年7月#1烟卤烟气数据

烟气量单位: 万立方米/天

| 日期 | 颗粒物 | | 二氧化硫 | | #1烟卤排放口 | | 烟气量 | 氧量% | 温度℃ | 湿度% | #1机组 | #2机组 | 负荷% |
|-----|-----|-----|------|-----|---------|------|------|------|------|-----|-----------|------------|-----|
| | 标志 | 折算 | 标志 | 折算 | 氮氧化物 | | | | | | | | |
| | | | | | 标志 | 折算 | | | | | | | |
| 1 | 3.4 | 4.2 | 2.6 | 3.2 | 24.5 | 30.7 | 3520 | 9.0 | 75.7 | 7.1 | 62 | 60 | |
| 2 | 3.4 | 4.1 | 2.9 | 3.6 | 23.0 | 28.3 | 3596 | 8.8 | 75.7 | 7.2 | 60 | 59 | |
| 3 | 3.1 | 3.9 | 2.7 | 3.4 | 22.8 | 28.5 | 3320 | 9.0 | 74.0 | 7.0 | 63 | 21:50机组停运 | |
| 4 | 4.0 | 4.9 | 3.4 | 4.1 | 20.7 | 25.7 | 2008 | 8.9 | 76.2 | 7.2 | 61 | 停运 | |
| 5 | 3.5 | 4.5 | 3.1 | 3.8 | 20.5 | 26.5 | 2082 | 9.3 | 75.8 | 7.1 | 63 | 停运 | |
| 6 | 3.1 | 4.0 | 2.4 | 3.0 | 19.9 | 25.3 | 2032 | 9.2 | 75.1 | 7.1 | 61 | 停运 | |
| 7 | 3.0 | 3.9 | 2.1 | 2.7 | 21.8 | 28.5 | 2041 | 9.5 | 75.1 | 7.3 | 61 | 停运 | |
| 8 | 3.7 | 4.2 | 3.7 | 4.1 | 26.2 | 30.5 | 2191 | 8.0 | 77.6 | 7.6 | 73 | 停运 | |
| 9 | 4.0 | 4.3 | 8.3 | 8.6 | 22.6 | 24.6 | 2311 | 7.1 | 78.0 | 7.5 | 77 | 停运 | |
| 10 | 4.4 | 4.7 | 6.9 | 7.4 | 23.8 | 25.8 | 2324 | 7.1 | 76.9 | 7.4 | 80 | 停运 | |
| 11 | 4.1 | 4.5 | 6.8 | 7.4 | 19.7 | 21.9 | 2195 | 7.5 | 75.8 | 6.8 | 73 | 停运 | |
| 12 | 4.5 | 5.0 | 8.5 | 9.0 | 22.1 | 24.6 | 1996 | 7.6 | 76.2 | 6.9 | 72 | 停运 | |
| 13 | 3.8 | 4.3 | 5.5 | 6.2 | 26.0 | 29.6 | 2029 | 7.9 | 76.3 | 6.9 | 72 | 停运 | |
| 14 | 3.1 | 3.7 | 2.7 | 3.2 | 23.5 | 27.8 | 1742 | 8.3 | 74.6 | 6.9 | 58 | 停运 | |
| 15 | 3.4 | 4.6 | 2.8 | 3.7 | 24.5 | 32.2 | 3229 | 9.4 | 72.1 | 6.8 | 60 | 7:41机组并网发电 | |
| 16 | 3.3 | 3.8 | 3.3 | 3.8 | 22.4 | 25.7 | 3563 | 7.9 | 76.2 | 7.1 | 64 | 60 | |
| 17 | 3.5 | 3.9 | 4.7 | 5.0 | 22.4 | 24.6 | 3687 | 7.3 | 77.4 | 7.2 | 68 | 68 | |
| 18 | 4.4 | 4.7 | 5.5 | 5.8 | 22.4 | 24.1 | 3801 | 7.1 | 78.6 | 7.3 | 71 | 73 | |
| 19 | 3.3 | 3.7 | 3.6 | 4.0 | 23.0 | 25.4 | 3592 | 7.4 | 75.8 | 6.8 | 67 | 63 | |
| 20 | 3.1 | 3.4 | 3.3 | 3.6 | 24.0 | 26.6 | 3568 | 7.5 | 75.5 | 6.6 | 64 | 63 | |
| 21 | 3.2 | 3.6 | 3.1 | 3.5 | 27.0 | 30.2 | 3460 | 7.6 | 75.5 | 6.6 | 62 | 58 | |
| 22 | 3.4 | 3.8 | 3.2 | 3.6 | 23.8 | 26.2 | 3613 | 7.4 | 76.3 | 6.6 | 65 | 65 | |
| 23 | 3.2 | 3.6 | 3.2 | 3.6 | 21.2 | 24.0 | 3443 | 7.7 | 75.0 | 6.5 | 60 | 59 | |
| 24 | 3.4 | 3.8 | 3.6 | 4.1 | 26.5 | 30.0 | 3350 | 7.7 | 75.2 | 6.3 | 58 | 58 | |
| 25 | 3.3 | 3.8 | 3.7 | 4.2 | 24.7 | 28.1 | 3389 | 7.8 | 75.0 | 6.3 | 58 | 58 | |
| 26 | 3.4 | 3.8 | 3.8 | 4.3 | 26.6 | 29.9 | 3411 | 7.6 | 75.7 | 6.4 | 59 | 59 | |
| 27 | 3.5 | 4.0 | 5.5 | 6.3 | 25.1 | 28.5 | 3443 | 7.8 | 75.9 | 6.5 | 61 | 60 | |
| 28 | 3.3 | 3.8 | 3.7 | 4.2 | 27.2 | 31.0 | 3389 | 7.8 | 75.1 | 6.6 | 59 | 55 | |
| 29 | 3.4 | 3.8 | 4.2 | 4.8 | 27.0 | 30.5 | 3334 | 7.7 | 76.1 | 6.6 | 57 | 58 | |
| 30 | 3.4 | 3.8 | 4.2 | 4.6 | 26.7 | 29.3 | 3655 | 7.3 | 77.2 | 6.6 | 64 | 68 | |
| 31 | 3.3 | 4.7 | 3.8 | 5.4 | 18.1 | 25.1 | 2057 | 12.4 | 64.9 | 5.7 | 23:11机组停运 | 18:43机组停运 | |
| 最大值 | 4.5 | 5.0 | 8.5 | 9.0 | 27.2 | 32.2 | 3801 | 12.4 | 78.6 | 7.6 | 80 | 73 | |
| 最小值 | 3.0 | 3.4 | 2.1 | 2.7 | 18.1 | 21.9 | 1742 | 7.1 | 64.9 | 5.7 | 57 | 55 | |
| 平均 | 3.5 | 4.1 | 4.1 | 4.6 | 23.5 | 27.4 | 2947 | 8.1 | 75.5 | 6.9 | 64 | 61 | |

深圳妈湾电力有限公司2019年7月#2烟囱烟气数据

烟气量单位: 万立方米/天

#2烟囱排放口

| 日期 | 颗粒物 | | 二氧化硫 | | 氮氧化物 | | 烟气量 | 氧量% | 温度℃ | 湿度% | #3机组 | #4机组 | 负荷% |
|-----|-----|-----|------|------|------|------|------|-----|------|-----|------|------------|-----|
| | 标态 | 折算 | 标态 | 折算 | 标态 | 折算 | | | | | | | |
| 1 | 3.3 | 3.4 | 17.3 | 17.4 | 18.3 | 18.0 | 4033 | 6.4 | 74.7 | 6.1 | 73 | 72 | |
| 2 | 3.1 | 3.2 | 18.9 | 19.1 | 19.4 | 19.9 | 4038 | 6.3 | 74.5 | 6.0 | 74 | 72 | |
| 3 | 2.7 | 2.9 | 10.8 | 11.7 | 19.2 | 20.9 | 3692 | 7.3 | 71.3 | 6.0 | 61 | 61 | |
| 4 | 3.2 | 3.2 | 16.7 | 16.6 | 18.7 | 18.9 | 4099 | 6.2 | 75.5 | 6.3 | 74 | 74 | |
| 5 | 2.8 | 2.8 | 15.1 | 14.9 | 21.1 | 21.2 | 4132 | 6.1 | 74.8 | 6.5 | 78 | 75 | |
| 6 | 2.6 | 2.6 | 16.0 | 16.2 | 18.4 | 18.9 | 4050 | 6.4 | 74.1 | 6.4 | 75 | 72 | |
| 7 | 2.6 | 2.6 | 12.1 | 12.4 | 23.6 | 24.2 | 3957 | 6.4 | 73.8 | 6.4 | 71 | 71 | |
| 8 | 2.7 | 2.7 | 14.3 | 14.1 | 25.3 | 25.7 | 4123 | 6.2 | 74.9 | 6.4 | 77 | 75 | |
| 9 | 2.8 | 2.8 | 19.3 | 19.2 | 22.3 | 22.3 | 4201 | 6.0 | 74.5 | 6.5 | 86 | 70 | |
| 10 | 3.0 | 3.0 | 14.9 | 15.1 | 20.5 | 20.8 | 4140 | 6.2 | 73.5 | 6.3 | 83 | 66 | |
| 11 | 3.2 | 3.1 | 16.9 | 16.7 | 19.4 | 19.4 | 4218 | 6.0 | 74.0 | 6.2 | 84 | 73 | |
| 12 | 3.1 | 3.2 | 17.4 | 17.7 | 19.0 | 19.6 | 4055 | 6.4 | 73.4 | 6.1 | 77 | 67 | |
| 13 | 2.8 | 2.9 | 16.1 | 16.5 | 18.3 | 18.9 | 4062 | 6.5 | 73.6 | 6.2 | 76 | 67 | |
| 14 | 2.7 | 2.8 | 13.6 | 14.2 | 20.5 | 21.8 | 3849 | 6.8 | 72.4 | 6.0 | 68 | 63 | |
| 15 | 3.1 | 3.1 | 14.4 | 14.4 | 19.5 | 19.7 | 4238 | 6.2 | 74.3 | 6.3 | 79 | 75 | |
| 16 | 3.2 | 3.2 | 14.0 | 13.7 | 22.7 | 22.8 | 4161 | 6.0 | 75.1 | 6.3 | 78 | 76 | |
| 17 | 3.4 | 3.4 | 14.7 | 14.3 | 23.8 | 23.9 | 4061 | 6.1 | 74.8 | 6.2 | 75 | 75 | |
| 18 | 3.5 | 3.6 | 16.6 | 16.6 | 22.6 | 23.3 | 4037 | 6.4 | 74.8 | 6.1 | 76 | 69 | |
| 19 | 3.3 | 3.5 | 12.3 | 12.8 | 23.4 | 25.0 | 3614 | 6.9 | 73.7 | 6.0 | 72 | 20:15机组停运 | |
| 20 | 2.8 | 3.1 | 7.3 | 7.8 | 25.4 | 27.8 | 2124 | 7.3 | 69.0 | 5.9 | 70 | 停运 | |
| 21 | 3.1 | 3.4 | 6.6 | 7.2 | 25.7 | 28.0 | 2177 | 7.1 | 70.1 | 6.1 | 73 | 停运 | |
| 22 | 3.3 | 4.0 | 6.2 | 7.0 | 21.6 | 25.8 | 3602 | 8.0 | 69.2 | 5.5 | 67 | 6:40机组并网发电 | |
| 23 | 3.4 | 3.4 | 7.9 | 7.8 | 25.5 | 25.6 | 4139 | 6.2 | 73.5 | 5.8 | 76 | 75 | |
| 24 | 3.6 | 3.7 | 9.8 | 9.9 | 24.2 | 25.2 | 3905 | 6.5 | 72.0 | 5.6 | 68 | 70 | |
| 25 | 3.4 | 3.5 | 9.9 | 9.8 | 24.8 | 25.1 | 4065 | 6.2 | 73.1 | 5.8 | 74 | 75 | |
| 26 | 3.4 | 3.5 | 8.0 | 8.1 | 22.1 | 22.8 | 4009 | 6.4 | 73.2 | 5.7 | 73 | 71 | |
| 27 | 3.6 | 3.6 | 9.3 | 9.4 | 23.1 | 23.5 | 4021 | 6.2 | 73.3 | 5.7 | 70 | 77 | |
| 28 | 3.3 | 3.5 | 6.6 | 6.8 | 23.7 | 24.8 | 3831 | 6.7 | 72.4 | 5.6 | 67 | 67 | |
| 29 | 3.6 | 3.8 | 7.6 | 7.8 | 24.0 | 25.0 | 3821 | 6.6 | 73.2 | 5.6 | 69 | 66 | |
| 30 | 4.0 | 4.0 | 8.1 | 8.1 | 24.5 | 24.9 | 4141 | 6.2 | 73.8 | 5.9 | 77 | 76 | |
| 31 | 3.4 | 3.6 | 8.6 | 9.0 | 22.4 | 23.9 | 3701 | 6.9 | 70.4 | 5.6 | 63 | 62 | |
| 最大值 | 4.0 | 4.0 | 19.3 | 19.2 | 25.7 | 28.0 | 4238 | 8.0 | 75.5 | 6.5 | 86 | 77 | |
| 最小值 | 2.6 | 2.6 | 6.2 | 6.8 | 18.3 | 18.9 | 2124 | 6.0 | 69.0 | 5.5 | 61 | 61 | |
| 平均 | 3.2 | 3.3 | 12.5 | 12.6 | 22.0 | 22.9 | 3881 | 6.5 | 73.3 | 6.0 | 74 | 71 | |

深圳妈湾电力有限公司2019年7月#3烟囱烟气数据

烟气量单位 万立方米/天

#3烟囱排放口

| 日期 | 颗粒物 | | 二氧化硫 | | 氮氧化物 | | 烟气量 | 氧量% | 温度℃ | 湿度% | #5机组 | #6机组 | 负荷% |
|-----|-----|-----|------|------|------|------|------|-----|------|-----|------|------|-----|
| | 标态 | 折算 | 标态 | 折算 | 标态 | 折算 | | | | | | | |
| | | | | | | | | | | | | | |
| 1 | 2.8 | 2.7 | 15.3 | 14.4 | 22.7 | 21.8 | 4022 | 5.3 | 78.0 | 5.7 | 81 | 72 | |
| 2 | 2.6 | 2.5 | 14.5 | 13.8 | 25.4 | 24.4 | 3842 | 5.4 | 76.9 | 5.8 | 77 | 66 | |
| 3 | 2.4 | 2.4 | 10.3 | 9.9 | 25.4 | 24.7 | 3572 | 5.5 | 74.2 | 5.9 | 70 | 59 | |
| 4 | 2.4 | 2.3 | 15.1 | 14.3 | 23.9 | 23.2 | 4047 | 5.5 | 77.7 | 6.2 | 77 | 74 | |
| 5 | 2.3 | 2.2 | 15.9 | 14.8 | 24.2 | 23.1 | 4035 | 5.3 | 77.9 | 6.3 | 78 | 75 | |
| 6 | 2.3 | 2.3 | 14.5 | 14.1 | 22.7 | 22.3 | 3528 | 5.7 | 75.8 | 6.0 | 66 | 62 | |
| 7 | 2.2 | 2.1 | 10.7 | 10.3 | 23.1 | 22.4 | 3680 | 5.5 | 76.2 | 6.3 | 73 | 62 | |
| 8 | 2.3 | 2.2 | 10.6 | 9.9 | 23.8 | 22.8 | 3888 | 5.3 | 77.1 | 6.1 | 76 | 70 | |
| 9 | 2.4 | 2.3 | 11.8 | 11.1 | 22.2 | 21.1 | 4381 | 5.2 | 78.5 | 6.3 | 83 | 84 | |
| 10 | 2.5 | 2.3 | 14.4 | 13.4 | 23.2 | 21.9 | 4400 | 5.1 | 77.4 | 6.2 | 85 | 83 | |
| 11 | 2.8 | 2.7 | 15.9 | 14.9 | 22.0 | 21.0 | 4295 | 5.3 | 77.0 | 5.7 | 80 | 82 | |
| 12 | 2.9 | 2.8 | 14.2 | 13.2 | 21.1 | 20.2 | 4116 | 5.4 | 77.8 | 5.6 | 79 | 77 | |
| 13 | 2.7 | 2.5 | 13.0 | 12.1 | 24.7 | 23.4 | 4166 | 5.2 | 78.0 | 5.8 | 81 | 79 | |
| 14 | 2.8 | 2.7 | 10.2 | 9.9 | 22.9 | 22.6 | 3565 | 5.8 | 76.5 | 5.9 | 69 | 60 | |
| 15 | 2.6 | 2.5 | 15.3 | 14.4 | 26.2 | 25.0 | 4153 | 5.3 | 77.7 | 5.9 | 81 | 77 | |
| 16 | 2.7 | 2.6 | 15.4 | 14.5 | 23.4 | 22.4 | 4104 | 5.3 | 78.2 | 5.7 | 81 | 74 | |
| 17 | 2.8 | 2.7 | 13.0 | 12.2 | 21.6 | 20.8 | 4036 | 5.4 | 78.3 | 5.8 | 78 | 74 | |
| 18 | 2.9 | 2.8 | 12.2 | 11.5 | 23.7 | 22.9 | 4069 | 5.4 | 78.6 | 5.6 | 79 | 76 | |
| 19 | 2.9 | 2.9 | 10.1 | 9.6 | 23.1 | 22.7 | 3881 | 5.7 | 77.0 | 5.4 | 71 | 70 | |
| 20 | 2.7 | 2.7 | 5.9 | 5.6 | 24.9 | 24.5 | 3922 | 5.7 | 75.8 | 5.5 | 71 | 71 | |
| 21 | 2.8 | 2.7 | 4.9 | 4.6 | 22.8 | 22.1 | 3901 | 5.4 | 76.8 | 5.5 | 76 | 68 | |
| 22 | 3.0 | 3.0 | 3.7 | 3.6 | 23.7 | 23.3 | 3748 | 5.7 | 77.2 | 5.3 | 69 | 68 | |
| 23 | 2.9 | 2.8 | 3.7 | 3.5 | 26.1 | 25.2 | 4118 | 5.4 | 77.8 | 5.4 | 78 | 76 | |
| 24 | 3.1 | 3.1 | 3.7 | 3.6 | 25.4 | 25.0 | 3814 | 5.6 | 78.1 | 5.4 | 72 | 69 | |
| 25 | 3.1 | 3.0 | 4.9 | 4.7 | 27.1 | 26.6 | 3807 | 5.7 | 77.1 | 5.5 | 74 | 66 | |
| 26 | 3.1 | 3.0 | 5.3 | 5.1 | 27.3 | 26.5 | 3794 | 5.5 | 77.2 | 5.4 | 74 | 65 | |
| 27 | 3.1 | 3.0 | 8.0 | 7.6 | 25.1 | 24.1 | 3902 | 5.4 | 77.6 | 5.4 | 83 | 65 | |
| 28 | 3.0 | 2.9 | 4.6 | 4.4 | 26.4 | 25.6 | 3702 | 5.5 | 76.1 | 5.3 | 74 | 63 | |
| 29 | 3.1 | 3.0 | 5.0 | 4.9 | 28.8 | 28.4 | 3595 | 5.8 | 76.6 | 5.3 | 69 | 60 | |
| 30 | 2.9 | 2.8 | 6.0 | 5.6 | 30.4 | 28.9 | 4142 | 5.3 | 77.8 | 5.5 | 80 | 76 | |
| 31 | 3.0 | 3.0 | 4.3 | 4.2 | 25.1 | 24.9 | 3550 | 5.9 | 74.7 | 5.4 | 65 | 59 | |
| 最大值 | 3.1 | 3.1 | 15.9 | 14.9 | 30.4 | 28.9 | 4400 | 5.9 | 78.6 | 6.3 | 85 | 84 | |
| 最小值 | 2.2 | 2.1 | 3.7 | 3.5 | 21.1 | 20.2 | 3528 | 5.1 | 74.2 | 5.3 | 65 | 59 | |
| 平均 | 2.7 | 2.7 | 10.1 | 9.5 | 24.5 | 23.7 | 3928 | 5.5 | 77.1 | 5.7 | 76 | 70 | |